

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 17/24-25

Dated: 09/03/2024

It is certified that an inspection team headed by Ankur Kumar

(Name of Officers with designation) from AE - JALNIGAM PHED

inspected the Maa Gayatri H.S. Sec. School, Churanwanpur

(Name & Address of the school) on 09/03/24 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. RWTL/SNA/0101/24 dated 08/03/24

of Regional Water Analytic Lab - Jalmigam VMS (PHED Lab) certified that

the Maa Gayatri H.S. Sec. School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 01 year

Signature with Seal: [Signature]

Name: Ankur Kumar

Designation: AE - JALNIGAM

Name & Address of the Office / Department: अधिसारी अभियन्ता

To The Manager / Principal,
Maa Gayatri H.S. Sec. School,
(Name & Address of the Institution)

खण्ड कार्यालय
उत्तर प्रदेश जल निगम (ग्रामीण)
जौनपुर

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies




* TEST REPORT *

Name & Address of Customer:		Customer Reference No.	No: 121/sk/29 Dated: 05/03/2024			
<u>Maa Gujrati Hr. Sec. School,</u> <u>Churawanpur, Baksha, Jaunpur, U.P.</u>		Sample Submitted by	S.P.Kannaujiya			
		Date of Sample Receipt	05/03/2024			
		Analysis Starting Date	05/03/2024			
		Analysis completion Date	08/03/2024			
		Discipline: Chemical Testing	Group: Water			
Test Report No.:	RWTL/SNG/0101/24-25	Date of Issue:	08/03/2024			
Registration no.:	RWTL/SNG/2425/REG2425/00101	Condition of Sample:	Unsealed			
Source:	NA	Quantity/Type of Bottle:	1000ml / Amber Colored Glass Bottle			
Scheme:	NA	Location/Depth:	RO plant Maa Gujrati Hr. Sec. School, Churawanpur, Baksha, Jaunpur, U.P./ NA			
Village:	Churawanpur	Habitation:	NA			
Block: -	Baksha	District:	Jaunpur			
Latitude:	NA	Longitude:	NA			
Sample Type: Treated Water						
Sr. No	Parameter	Result	As per 15-10500:2012 (2 nd Rev.)		Unit	Reference Method:
			Acceptable Limit	Permissible Limit		
1	pH	7.75	6.5-8.5	No Relaxation		IS 3025 (Part 11-1993) Electrometric Method
2	Colour	01	5	15	Hazen	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Disagreeable		IS 3025 (Part 5 -2018) (Second Revision)
4	TDS	280	500	2000	mg/l	IS 3025 (Part 16-1984) Gravimetric Method
5	Turbidity	0.19	1	5	NTU	IS 3025 (Part 10-1984) Nephelometric Method
6	Alkalinity	12	200	600	mg/l	IS 3025 (Part 23-1986) Indicator Method
7	Hardness	120	200	600	mg/l	IS 3025 (Part 21-2019) EDTA Method
8	Calcium	27	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
9	Magnesium	13	30	100	m\$/l	APHA (23rd Ed.2017) Method: 3500-Mg+2 B By Calculation Method
10	Chloride	88	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition:

1. This report is referring only to the tested sample and for applicable parameter.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed)
5. * Value not available or test not performed for this parameter.


Dr. Ramesh Yadav
Quality Manager
Authorized Signatory
For, Regional Water Analysis,
Laboratory Jan Nigam Varanasi – UP.

----- End of the Test Report -----